

| C•CURE System General Activity Monitor (User: Manager)                     |  |                                          |
|----------------------------------------------------------------------------|--|------------------------------------------|
| Login/Logout Non-hardware Status Hardware Status Reports View Options Help |  |                                          |
|                                                                            |  |                                          |
| Mon                                                                        |  |                                          |
| 16:06:56                                                                   |  | M1-2 PULL activated                      |
| Mon                                                                        |  |                                          |
| 16:06:56                                                                   |  | M1-2 Fire Alarm Event activated          |
| Mon                                                                        |  | M1-2 PULL STATION in ALARM               |
| 16:07:11                                                                   |  | M1-36 shorted loop                       |
| Mon                                                                        |  |                                          |
| 16:07:11                                                                   |  | M1-36 activated                          |
| Mon                                                                        |  |                                          |
| 16:07:31                                                                   |  | System Supervisory Event activated       |
| Mon                                                                        |  | System Shows SUPERVISORY Alarm(s) Active |
| 16:07:32                                                                   |  | M1-44 activated                          |
| Mon                                                                        |  |                                          |
| 16:07:54                                                                   |  | M1-2 PULL shorted loop cleared           |
| Mon                                                                        |  |                                          |



C•CURE® 800 provides advanced, seamless integration with the 4100U Fire Detection and Alarm Panel from SimplexGrinnell, allowing customers to monitor their important fire devices from the C•CURE 800 guard station.

The SimplexGrinnell 4100U Fire Panel is a high-end, next-generation distributed network system that combines superior fire protection and information management with lower costs of installation, maintenance and ownership.

The union of this high-end fire system and the C•CURE 800 through a bi-directional interface provides extensive system integration opportunities, including the ability to receive secondary annunciation from the linked fire alarms. Currently, the 4100U Fire Panel can support up to 2000 signals through a centralized RS-232 connection. This allows security personnel to view all critical events, including access violations, video alarms, and now fire alarms, from one centralized station. As per fire regulations, no control is provided for the security system operators to silence alarms or reset signals to a cleared state on the fire system.

As with other important events in the C•CURE 800, all fire alarm activity is stored in the system's detailed journal for future investigative reporting.

## KEY FEATURES

- Provides ability to view all critical security and fire events in one station on one screen
- General purpose bi-directional serial interface provides seamless integration with industry-leading 4100U fire panel from SimplexGrinnell
- All fire alarm activity can be logged in the security journal allowing both life safety and security events to be reviewed together in future investigative reporting

## SPECIFICATIONS

**C•CURE 800/8000 Server Recommended Minimum Requirements**  
 SimplexGrinnell's 4100U Fire Panel will support connection to a single non-redundant C•CURE 800 System.

### Processor

Model Number 1 through 10 . . . 1.5 GHz Intel Pentium III or higher

Model Number 20 through 40 . . . 1.8 GHz Intel Pentium III or higher

Model 8000 and 8000 Plus . . . 2.4 GHz Intel Pentium IV or higher

Free Hard Disk Space . . . . . 3.0 GB

### Memory

Model Number 1 through 40 . . . . 1 GB RAM

Model 8000 and 8000 Plus . . . . . 2 GB RAM

Network Card . . . . . 10/100 base-T

CD-ROM Drive . . . . . 10X

Monitor/Video Adapter board . . . 17" SVGA (1024 x 768)

Operating Systems . . . . . Windows® 2000/XP  
 Professional (Service Pack 4),  
 Windows 2003 Server

Mouse . . . . . PS/2 bus type

Ports . . . . . 2 serial, 1 parallel, USB  
 (with C•CURE 800 v8.x a USB  
 port is required)

Backup . . . . . Tape or CDRW  
 Modem . . . . . 56.7 Kbps  
 Sentinel . . . . . Supplied by Software House  
 Digiboard . . . . . 8 port (Models 20/30/40)  
 specifications

### C•CURE 800/8000 Client Recommended Requirements

Processor . . . . . 1.5 GHz Intel Pentium or higher

Free Hard Disk Space . . . . . 2.0 GB

Memory . . . . . 512 MB RAM

Network Card . . . . . 10bT

CD-ROM Drive . . . . . 10X

Monitor/Video Adapter board . . . 17" SVGA (1024 x 768),  
 64 MB RAM

Operating Systems . . . . . Windows® 2000 Professional  
 (Service Pack 4), Windows XP  
 Professional (Service Pack 2)

Mouse . . . . . PS/2 bus type

Note: This feature can only be implemented in C•CURE 800/8000 v8.0 and later. It is recommended that customers use the most current firmware release for each controller.

